

### Standard Features:

- Air bar diffuser with versatile airflow capability
- Duct Bracket mount frame style with 1 3/4" flange and flanged end caps
- Multiple fastening locations for each diffuser
- Allows for higher volume airflow while minimizing pressure loss
- Minimum length 12"
- Unlimited continuous sections available with butt joints
- Soft White

### Manufacturing Requirements:

Length \_\_\_\_\_ feet inches

Supply – Adjustable split 2-piece Air Gate controllers for directional air volume control (LAB-T6-S)

Return – less Air Gates (LAB-T6-R)

Number of slots: 1 2

Slot Width: 1" 1 1/2" 2" 2 1/2" 3"

### Options:

Flat end caps

90° Mitered corners

### Finishes:

#### STANDARD COLORS

- ☐ Soft White
- ☐ Driftwood Tan
- ☐ Mill Finish

#### DESIGNER COLORS

- ☐ Black
- ☐ Bronze
- ☐ Storm Gray
- ☐ Cement Gray

- ☐ Aluminum Paint
- ☐ Coffee Tan
- ☐ Warm White
- ☐ Glossy White

### Dimensions (in inches)

# OF SLOTS	SLOT WIDTH (A)	OVERALL WIDTH (B)	WIDTH OF BACK (C)
1	1	4 1/2	3 1/8
	1 1/2	5	3 5/8
	2	5 1/2	4 1/8
	2 1/2	6	4 5/8
	3	6 1/2	5 1/8
2	1	7 1/2	6 1/8
	1 1/2	8 1/2	7 1/8
	2	9 1/2	8 1/8
	2 1/2	10 1/2	9 1/8
	3	11 1/2	10 1/8

Note ID lengths 1/4" undersized nominal

### Install Notes:

Plenum must be installed before diffuser install. The Type 6 Duct Mount is an effective and quick mounting mechanism. Attach the duct bracket to the LAB-T6 only tapping the fastening screws enough to hold the LAB-T6 and bracket together. Once the brackets have been attached to the LAB-T6 and the unit is set into place, the duct brackets will snap into position. The rolled edges of the duct support the duct bracket, holding it in place, while the fastening screws are threaded in the remainder of the way to pull the LAB-T6 tight to the finished surface. Duct brackets and mounting screws will ship with the LAB-T6.

### Additional Information:

### Submittal Notes

Project / Location:

Engineer:


Architect:

Contractor:

# Linear Air Bar Diffuser Submittal

## Duct Bracket Mount Frame with Metal Plenum (Type 6)

MODEL: LAB-T6-SDP, LAB-T6-DP



### LINEAR AIR BAR DIFFUSER Standard Features:

- Air bar diffuser with versatile airflow capability
- Duct Bracket mount frame style with 1 3/4" flange and flanged end caps
- Multiple fastening locations for each diffuser
- Allows for higher volume airflow while minimizing pressure loss
- Minimum length 12"
- Unlimited continuous sections available
- Soft White

### Manufacturing Requirements:

Length \_\_\_\_\_ feet \_\_\_\_\_ inches

Supply – Adjustable split 2-piece Air Gate controllers for directional air volume control (LAB-T6-S)

Return – less Air Gates (LAB-T6-R)

Number of slots: 1 2

Slot Width: 1" 1 1/2" 2" 2 1/2" 3"

### Options:

Flat end caps  
90° Mitered corners

### Finishes:

☐ Soft White  
☐ Driftwood Tan  
☐ Mill Finish  
Designer Color \_\_\_\_\_

### METAL PLENUM Standard Features:

- 24 gauge galvanized steel plenum, with hemmed rail
- Minimum length 12" and maximum single piece length is 6'
- Metal plenum ships separately from diffuser and requires field assembly

### Manufacturing Requirements:

Short Distribution Plenum – SDP (standard, height set at 9")

Distribution Plenum – DP (height = inlet diameter + 4")

Internal insulation: 1/2" fiberglass (std) – L 1/2" fiberglass w/foil back– LEX  
Closed cell – C

External insulation: 1/2" fiberglass w/foil back (std) – EX  
1" fiberglass – 1" – EX1

No insulation – N

Oval inlet sizes: 5" 6" 7" 8" 10" 12" 14" 16" (SDP and DP)

Round inlet sizes: 5" 6" 7" 8" 10" 12" 14" 16" (DP only)

No inlet (SDP and DP)

### Options:

Damper: Rod Twist Cord  
Perforated steel baffle\* – Type A - #69  
Solid steel baffle\* – Type B - #70  
\*Optional performance baffles improve comfort in short throw applications by widening the spread of the discharge air

### Install Notes:

Metal Plenum must be installed before the diffuser is installed. The Type 6 Duct Mount is an effective and quick mounting mechanism. Attach the duct bracket to the LAB-T6 only tapping the fastening screws enough to hold the LAB-T6 and bracket together. Once the brackets have been attached to the LAB-T6 and the unit is set into place, the duct brackets will snap into position. The rolled edges of the duct support the duct bracket, holding it in place, while the fastening screws are threaded in the remainder of the way to pull the LAB-T6 tight to the finished surface. Duct brackets and mounting screws will ship with the LAB-T6.

Dimensions (in inches)				
# OF SLOTS	SLOT WIDTH (A)	OVERALL WIDTH (B)	SDP WIDTH (J)	DP WIDTH (K)
1	1	4 1/2	3 3/4	4 3/4
	1 1/2	5	4 1/4	5 1/4
	2	5 1/2	4 3/4	5 3/4
	2 1/2	6	5 1/4	6 1/4
	3	6 1/2	5 3/4	6 3/4
2	1	7 1/2	6 3/4	7 3/4
	1 1/2	8 1/2	7 3/4	8 3/4
	2	9 1/2	8 3/4	9 3/4
	2 1/2	10 1/2	9 3/4	10 3/4
	3	11 1/2	10 3/4	11 3/4

Note: Diffuser ID lengths 1/4" undersized nominal. Metal plenum manufactured to nominal dimensions. If duct opening is 48", plenum will be 48" and diffuser will be 47-3/4".

### Additional Information:

### Submittal Notes

Project / Location:

Engineer:


Architect:

Contractor:

# Commercial Submittal


## Mitered Corner Linear Air Bar (1 Slot Configuration)

LAB Mitered Corner  
1 Slot Types 2, 4



Dimensions (in inches)			
Type 2, 4			
SLOT WIDTH	(L)	(B)	(D)
1	9	4 1/2	4 1/2
1 1/2	9	5	4
2	9	5 1/2	3 1/2
2 1/2	9	6	3
3	9	6 1/2	2 1/2

LAB Mitered Corner  
1 Slot Type 3



Dimensions (in inches)			
Type 3			
SLOT WIDTH	(L)	(B)	(D)
1	10	5 1/2	4 1/2
1 1/2	10	6	4
2	10	6 1/2	3 1/2
2 1/2	10	7	3
3	10	7 1/2	2 1/2

### Additional Information:

### Submittal Notes

Project / Location:

Engineer:


Architect:

Contractor:

# Commercial Submittal


## Mitered Corner Linear Air Bar (2 Slot Configuration)

LAB Mitered Corner  
2 Slot Types 2, 4



Dimensions (in inches)			
Type 2, 4			
SLOT WIDTH	(L)	(B)	(D)
1	18	7 1/2	10 1/2
1 1/2	18	8 1/2	9 1/2
2	18	9 1/2	8 1/2
2 1/2	18	10 1/2	7 1/2
3	18	11 1/2	6 1/2

LAB Mitered Corner  
2 Slot Type 3



Dimensions (in inches)			
Type 3			
SLOT WIDTH	(L)	(B)	(D)
1	19	8 1/2	10 1/2
1 1/2	19	9 1/2	9 1/2
2	19	10 1/2	8 1/2
2 1/2	19	11 1/2	7 1/2
3	19	12 1/2	6 1/2

### Additional Information:

### Submittal Notes

Project / Location:

Engineer:

Architect:

Contractor: